
Mayville Centre - temperature - Main Hall (29.10.2012 - 13.11.2012)
TEMPERATURE (*C)
30
25
20
15
10
5
0
INTERNAL TEMPERATURES (*C)
typical 1°C swing in internal temperature in unheated, double height main hall
typical 5-10°C diurnal swing in external temperatures
EXTERNAL TEMPERATURE (*C)
door left open for hall access
door open for children's creche
door left open during exercise class
door left open for children's creche
© bere:architects 2012
External DegC
Hall DegC
29/09/2012 00:00
30/09/2012 00:35
01/10/2012 01:10
02/10/2012 01:45
03/10/2012 02:20
04/10/2012 02:55
05/10/2012 03:30
06/10/2012 04:05
07/10/2012 04:40
08/10/2012 05:15
09/10/2012 05:50
10/10/2012 06:25
11/10/2012 07:00
12/10/2012 07:35
13/10/2012 08:10
14/10/2012 08:45
15/10/2012 09:20
16/10/2012 09:55
17/10/2012 10:30
18/10/2012 11:05
19/10/2012 11:40
20/10/2012 12:15
21/10/2012 12:50
22/10/2012 13:25
23/10/2012 14:00
24/10/2012 14:35
25/10/2012 15:10
26/10/2012 15:45
27/10/2012 16:20
28/10/2012 16:55
29/10/2012 17:30
30/10/2012 18:05
31/10/2012 18:40
01/11/2012 19:15
02/11/2012 19:50
03/11/2012 20:25
04/11/2012 21:00
05/11/2012 21:35
06/11/2012 22:10
07/11/2012 22:45
08/11/2012 23:20
09/11/2012 23:55
11/11/2012 00:30
12/11/2012 01:05
13/11/2012 01:40